

# Water Detector Installation Instructions

The water detector incorporates microchip technology and either gold-plated electrodes (single point detection either local or remote) or detection cable (continuous detection). This device can be operated from either an AC or DC supply and has a built-in fail-safe mechanism. The output of the detector is a reverse acting form "C" relay contact capable of switching 2 Amps at 250 Vac.

Fail-safe circuitry is incorporated in the WD-100 to signal an alarm condition in the event of a power loss or internal malfunction. This offers maximum security of the monitoring system.

## Installation

For the single point device adjust the legs of the enclosure so that the probes on the bottom are at the desired detection height and secure the enclosure at the holes in the adjustable feet.

For the continuous cable device lay the cable on the surface to be monitored and use the supplied cable clamps to affix the cable to the surface. The cable can also be wrapped around a pipe. The enclosure should be mounted where it will stay dry.

For the remote probe device use a screw (not included) to mount the terminal block with the probes in the area to be monitored. The enclosure should be mounted where it will stay dry.

## SPECIFICATIONS

|                         |                                                                                    |
|-------------------------|------------------------------------------------------------------------------------|
| Power Supply            | 14 - 32 V ac/dc                                                                    |
| Power Consumption       | 60 mA max @ 24 Vdc<br>(no water)                                                   |
| Operating Temperature   | -40 to 85 C (-40 to 185 F)                                                         |
| Output Rating           | Form "C" contacts<br>2 Amps @ 250 Vac (General use)<br>2 Amps @ 30 Vdc (Resistive) |
| Continuous Cable Rating | CL2P (UL)                                                                          |

| Fluids than can be detected | Fluids that can't be detected |
|-----------------------------|-------------------------------|
| City water                  | Pure water                    |
| Sea water                   | Gasoline                      |
| Copper sulfate solution     | Oil                           |
| Weak acid                   | Brake fluid                   |
| Weak base                   | Alcohol                       |
| Household ammonia           | Ethylene glycol               |
| Water & glycol mixture      | Paraffin                      |
| Wet soil                    | Dry soil                      |
| Coffee                      | Whiskey                       |

**Note : The relay output state is shown in the powered state with no water present.**

### WIRING

#### Supply

|               |                       |
|---------------|-----------------------|
| <b>POWER</b>  | <b>Positive DC/AC</b> |
| <b>COMMON</b> | <b>Common/AC</b>      |

#### Relay Output

|            |                        |
|------------|------------------------|
| <b>NC</b>  | <b>Normally Closed</b> |
| <b>COM</b> | <b>Common</b>          |
| <b>NO</b>  | <b>Normally Open</b>   |

#### Remote Probe/Cable

|          |                    |
|----------|--------------------|
| <b>L</b> | <b>Remote Lead</b> |
| <b>H</b> | <b>Remote Lead</b> |

