



**MANUFACTURER:** Greystone Energy Systems Inc.  
150 English Drive, Moncton, New Brunswick, Canada, E1E 4G7

**DECLARES THAT THE FOLLOWING PRODUCT:**

**PRODUCT NAME:** Gage Pressure Transmitter  
**MODEL NUMBERS:** PGS100A-XXXX  
(where XXXX designates the pressure range)



**CONFORMS TO THE FOLLOWING DIRECTIVES AND STANDARDS:**

**RoHS2 Directive: 2011/65/EU** Restriction of Hazardous Substances  
**EMC Directive: 2004/108/EC** Electromagnetic Compatibility

Specification	Test Method	Description
EN 61326-1:2006 and EN 61326-2-3:2006	CISPR 11/EN 55011	Conducted and Radiated Emissions
	IEC 61000-4-2	Electrostatic Discharge (ESD)
	IEC 61000-4-3	Radiated Immunity
	IEC 61000-4-4	Electrical Fast Transient and Bursts (EFT)
	IEC 61000-4-6	Conducted Immunity



*I, the undersigned, hereby declare that the equipment specified above conforms to the above Directive and Standard.*

Lucas Steeves, Engineering Manager

December 22, 2015  
Moncton, NB, Canada