



MANUFACTURER: Greystone Energy Systems Inc.
150 English Drive, Moncton, New Brunswick, Canada, E1E 4G7

DECLARES THAT THE FOLLOWING PRODUCT:

PRODUCT NAME: TH & TL High & Low limit Thermostat Series

SERIES:

-AP All Purpose	-DC Flexible Copper Duct Avg	-DF Flex-Duct Avg
-DR Rigid Duct Avg	-FL Flying Lead	-GL Glass
-OS Outside	-RP Remote Probe Strap-On	-SO Strap-On

MODEL NUMBERS: THAA-X-YY-Z-BB & TLAA-X-YY-Z-BB
(where AA designates the Series)
(where X designates Enclosure with or Thread adapter & cable gland fitting)
(where YY designates Sensor type)
(where Z designates Probe Length, if applicable)
(where BB designates with Temperature Range)



CONFORMS TO THE FOLLOWING DIRECTIVES AND STANDARDS:

RoHS 3 Directive: 2015/863 Restriction of Hazardous Substances

EMC Directive: 2014/30/EU Electromagnetic Compatibility

Specification	Test Method	Description
EN 61326-1:2013	CISPR 11:2015 +A1:2016	Conducted and Radiated Emissions
	IEC 61000-4-2:2008	Electrostatic Discharge (ESD)
	IEC 61000-4-3:2010	Radiated Immunity
	IEC 61000-4-4:2012	Electrical Fast Transient and Bursts (EFT)
	IEC 61000-4-6:2013	Conducted Immunity
	IEC 61000-4-8:2009	Magnetic Field Immunity

FCC 15.109(g):2019 ANSI C63.4:2014 Conducted and Radiated Emissions

ICES-003:2016.2017 ANSI C63.4:2014 Conducted and Radiated Emissions



I, the undersigned, hereby declare that the equipment specified above conforms to the above Directive and Standard.

Lucas Steeves, Engineering Manager

May 8, 2019
Moncton, NB, Canada