



**MANUFACTURER:** Greystone Energy Systems Inc.  
150 English Drive, Moncton, New Brunswick, Canada, E1E 4G7

**DECLARES THAT THE FOLLOWING PRODUCT:**

**PRODUCT NAME:** Temperature Transmitter Series

**MODEL NUMBERS:** TX-YY-X-ZZ-S-T-UUU (where YY designates Mounting Style)  
(where X designates Enclosure)  
(where ZZ designates Sensor)  
(where S designates Probe Length)  
(where T designates Output Type)  
(where UUU designates Temp Range)



**CONFORMS TO THE FOLLOWING DIRECTIVES AND STANDARDS:**

**RoHS 3 Directive: 2015/863** Restriction of Hazardous Substances

**EMC Directive: 2014/30/EU** Electromagnetic Compatibility

Specification	Test Method	Description
EN 61326-1:2013	CISPR 11:2015 +A1:2016	Conducted and Radiated Emissions
	IEC 61000-4-2:2008	Electrostatic Discharge (ESD)
	IEC 61000-4-3:2010	Radiated Immunity
	IEC 61000-4-4:2012	Electrical Fast Transient and Bursts (EFT)
	IEC 61000-4-6:2013	Conducted Immunity
	IEC 61000-4-8:2009	Magnetic Field Immunity



*I, the undersigned, hereby declare that the equipment specified above conforms to the above Directive and Standard.*

Lucas Steeves, Engineering Manager

November 15, 2018  
Moncton, NB, Canada